

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 **2025**

Influent Flow and Loading

1. Monthly Average Flows and BOD Loadings

1.1 Verify the following monthly flows and BOD loadings to your facility.

Influent No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average BOD Concentration mg/L	x	8.34	=	Influent Monthly Average BOD Loading, lbs/day
January	0.0564	x	290	x	8.34	=	136
February	0.0541	x	256	x	8.34	=	116
March	0.0588	x	447	x	8.34	=	219
April	0.0552	x	251	x	8.34	=	116
May	0.0518	x	323	x	8.34	=	140
June	0.0556	x	271	x	8.34	=	126
July	0.0754	x	257	x	8.34	=	161
August	0.0508	x	272	x	8.34	=	116
September	0.0543	x	268	x	8.34	=	121
October	0.0529	x	226	x	8.34	=	100
November	0.0505	x	255	x	8.34	=	107
December	0.0487	x	279	x	8.34	=	113

2. Maximum Monthly Design Flow and Design BOD Loading

2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	.105	x	90	=	0.0945
		x	100	=	.105
Design BOD, lbs/day	229	x	90	=	206.1
		x	100	=	229

2.2 Verify the number of times the flow and BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times BOD was greater than 90% of design	Number of times BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	0	0
March	1	0	0	1	0
April	1	0	0	0	0
May	1	0	0	0	0
June	1	0	0	0	0
July	1	0	0	0	0
August	1	0	0	0	0
September	1	0	0	0	0
October	1	0	0	0	0
November	1	0	0	0	0
December	1	0	0	0	0
Points per each		2	1	3	2
Exceedances		0	0	1	0
Points		0	0	3	0
Total Number of Points					3

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 2025

3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?
 Yes Enter last calibration date (MM/DD/YYYY)

No

If No, please explain:

4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

Yes

No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

Yes

No

If Yes, please explain:

5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks

Holding Tanks

Grease Traps

Yes

Yes

Yes

No

No

No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

Yes

gallons

No

Holding Tanks

Yes

gallons

No

Grease Traps

Yes

gallons

No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

Yes

No

If yes, describe the situation and your community's response.

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 2025

- Yes
- No

If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.

Total Points Generated	3
Score (100 - Total Points Generated)	97
Section Grade	A

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 **2025**

Effluent Quality and Plant Performance (BOD/CBOD)

1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 003	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	79	1	1	1
February	30	27	9	1	0	0
March	30	27	3	1	0	0
April	30	27	5	1	0	0
May	30	27	6	1	0	0
June	30	27	4	1	0	0
July	30	27	5	1	0	0
August	30	27	5	1	0	0
September	30	27	26	1	0	0
October	30	27	48	1	1	1
November	30	27	8	1	0	0
December	30	27	8	1	0	0

* Equals limit if limit is <= 10

Months of discharge/yr	12		
Points per each exceedance with 12 months of discharge		7	3
Exceedances		2	2
Points		14	6
Total number of points			20

20

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is 12/6 = 2.0

1.2 If any violations occurred, what action was taken to regain compliance?

Repaired broken air line in SBR tank

2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

Yes Enter last calibration date (MM/DD/YYYY)

2025-10-09

No

If No, please explain:

3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

Broken air line in SBR tank

4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

Yes

No

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 2025

<p>If Yes, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>
<p>4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test?</p> <p><input type="radio"/> Yes</p> <p><input checked="" type="radio"/> No</p> <p>If Yes, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>
<p>4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity?</p> <p><input type="radio"/> Yes</p> <p><input type="radio"/> No</p> <p><input checked="" type="radio"/> N/A</p> <p>Please explain unless not applicable:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>

Total Points Generated	20
Score (100 - Total Points Generated)	80
Section Grade	C

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:

6/1/2026

2025

Effluent Quality and Plant Performance (Total Suspended Solids)

1. Effluent Total Suspended Solids Results

1.1 Verify the following monthly average effluent values, exceedances, and points for TSS:

Outfall No. 003	Monthly Average Limit (mg/L)	90% of Permit Limit >10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	73	1	1	1
February	30	27	14	1	0	0
March	30	27	2	1	0	0
April	30	27	2	1	0	0
May	30	27	3	1	0	0
June	30	27	2	1	0	0
July	30	27	1	1	0	0
August	30	27	2	1	0	0
September	30	27	5	1	0	0
October	30	27	15	1	0	0
November	30	27	7	1	0	0
December	30	27	6	1	0	0

* Equals limit if limit is ≤ 10

Months of Discharge/yr	12		
Points per each exceedance with 12 months of discharge:		7	3
Exceedances		1	1
Points		7	3
Total Number of Points			10

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Repaired broken air line in SBR tank

10

Total Points Generated	10
Score (100 - Total Points Generated)	90
Section Grade	B

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 **2025**

Effluent Quality and Plant Performance (Ammonia - NH3)

1. Effluent Ammonia Results

1.1 Verify the following monthly and weekly average effluent values, exceedances and points for ammonia

Outfall No. 003	Monthly Average NH3 Limit (mg/L)	Weekly Average NH3 Limit (mg/L)	Effluent Monthly Average NH3 (mg/L)	Monthly Permit Limit Exceedance	Effluent Weekly Average for Week 1	Effluent Weekly Average for Week 2	Effluent Weekly Average for Week 3	Effluent Weekly Average for Week 4	Weekly Permit Limit Exceedance
January	32	73	39.715	1	29.05	31.167	52.633	45.667	0
February	32	73	14.567	0	26.8	16.3	7.733	7.433	0
March	32	73	2.142	0	1.567	3.6	1.367	2.033	0
April	32	73	2.636	0	1.067	5.4	3.933	.9	0
May	32	73	1.531	0	2.033	1.633	.033	1.733	0
June	108	108	4.342	0	0	6	8.767	2.6	0
July	108	108	3.587	0	2.733	1.567	3.133	2.5	0
August	108	108	7.95	0	22.4	.8	4.7	3.9	0
September	108	108	8.808	0	8.933	.133	1.667	19.1	0
October	32	73	16.821	0	27.7	17.6	5.3	14.933	0
November	32	73	20.375	0	16.533	13.233	26.4	25.333	0
December	32	73	25.98	0	21.867	25.033	38.3	22.267	0

10

Points per each exceedance of Monthly average:	10
Exceedances, Monthly:	1
Points:	10
Points per each exceedance of weekly average (when there is no monthly average):	2.5
Exceedances, Weekly:	0
Points:	0
Total Number of Points	10

NOTE: Limit exceedances are considered for monthly OR weekly averages but not both. When a monthly average limit exists it will be used to determine exceedances and generate points. This will be true even if a weekly limit also exists. When a weekly average limit exists and a monthly limit does not exist, the weekly limit will be used to determine exceedances and generate points.

1.2 If any violations occurred, what action was taken to regain compliance?

Repaired broken air line in SBR tank

Total Points Generated	10
Score (100 - Total Points Generated)	90
Section Grade	B

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 **2025**

Effluent Quality and Plant Performance (Phosphorus)

1. Effluent Phosphorus Results

1.1 Verify the following monthly average effluent values, exceedances, and points for Phosphorus

Outfall No. 003	Monthly Average phosphorus Limit (mg/L)	Effluent Monthly Average phosphorus (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance
January	1.9	3.905	1	1
February	1.9	0.516	1	0
March	1.9	0.088	1	0
April	1.9	0.194	1	0
May	1.9	0.140	1	0
June	1.9	0.115	1	0
July	1.9	0.089	1	0
August	1.9	0.109	1	0
September	1.9	0.269	1	0
October	1.9	0.516	1	0
November	1.9	0.299	1	0
December	1.9	0.203	1	0
Months of Discharge/yr			12	
Points per each exceedance with 12 months of discharge:				10
Exceedances				1
Total Number of Points				10

10

NOTE: For systems that discharge intermittently to waters of the state, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Repaired broken air line in SBR tank

Total Points Generated	10
Score (100 - Total Points Generated)	90
Section Grade	B

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 2025

Biosolids Quality and Management

1. Biosolids Use/Disposal

1.1 How did you use or dispose of your biosolids? (Check all that apply)

- Land applied under your permit
- Publicly Distributed Exceptional Quality Biosolids
- Hauled to another permitted facility
- Landfilled
- Incinerated
- Other

NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.

1.1.1 If you checked Other, please describe:

2. Land Application Site

2.1 Last Year's Approved and Active Land Application Sites

2.1.1 How many acres did you have?

97.7 acres

2.1.2 How many acres did you use?

30 acres

2.2 If you did not have enough acres for your land application needs, what action was taken?

2.3 Did you overapply nitrogen on any of your approved land application sites you used last year?

- Yes (30 points)
- No

2.4 Have all the sites you used last year for land application been soil tested in the previous 4 years?

- Yes
- No (10 points)
- N/A

0

3. Biosolids Metals

Number of biosolids outfalls in your WPDES permit:

3.1 For each outfall tested, verify the biosolids metal quality values for your facility during the last calendar year.

Outfall No. 002 - LIQUID SLUDGE

Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75											8.12			0	0
Cadmium		39	85											<.02			0	0
Copper		1500	4300											329			0	0
Lead		300	840											<.201			0	0
Mercury		17	57											.39			0	0
Molybdenum	60		75											<.3	0			0
Nickel	336		420											<3.4	0			0
Selenium	80		100											<.3	0			0
Zinc		2800	7500											538			0	0

3.1.1 Number of times any of the metals exceeded the high quality limits OR 80% of the limit for molybdenum, nickel, or selenium = 0

- Exceedence Points
- 0 (0 Points)

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 2025

- 1-2 (10 Points)
- > 2 (15 Points)
- 3.1.2 If you exceeded the high quality limits, did you cumulatively track the metals loading at each land application site? (check applicable box)
 - Yes
 - No (10 points)
 - N/A - Did not exceed limits or no HQ limit applies (0 points)
 - N/A - Did not land apply biosolids until limit was met (0 points)
- 3.1.3 Number of times any of the metals exceeded the ceiling limits = 0 Exceedence Points
 - 0 (0 Points)
 - 1 (10 Points)
 - > 1 (15 Points)
- 3.1.4 Were biosolids land applied which exceeded the ceiling limit?
 - Yes (20 Points)
 - No (0 Points)
- 3.1.5 If any metal limit (high quality or ceiling) was exceeded at any time, what action was taken? Has the source of the metals been identified?

0

4. Pathogen Control (per outfall):

4.1 Verify the following information. If any information is incorrect, use the Report Issue button under the Options header in the left-side menu.

Outfall Number:	002
Biosolids Class:	B
Bacteria Type and Limit:	Fecal Coliform
Sample Dates:	01/01/2025 - 12/31/2025
Density:	144,899
Sample Concentration Amount:	CFU/G TS
Requirement Met:	Yes
Land Applied:	Yes
Process:	Aerobic Digestion
Process Description:	180 days or greater

0

4.2 If exceeded Class B limit or did not meet the process criteria at the time of land application.

4.2.1 Was the limit exceeded or the process criteria not met at the time of land application?

- Yes (40 Points)
- No

If yes, what action was taken?

5. Vector Attraction Reduction (per outfall):

5.1 Verify the following information. If any of the information is incorrect, use the Report Issue button under the Options header in the left-side menu.

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 2025

Outfall Number:	002	0
Method Date:	12/31/2025	
Option Used To Satisfy Requirement:	Incorporation when land apply	
Requirement Met:	Yes	
Land Applied:	Yes	
Limit (if applicable):		
Results (if applicable):		
<p>5.2 Was the limit exceeded or the process criteria not met at the time of land application?</p> <p><input type="radio"/> Yes (40 Points)</p> <p><input checked="" type="radio"/> No</p> <p>If yes, what action was taken?</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>		
<p>6. Biosolids Storage</p> <p>6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site?</p> <p><input checked="" type="radio"/> >= 180 days (0 Points)</p> <p><input type="radio"/> 150 - 179 days (10 Points)</p> <p><input type="radio"/> 120 - 149 days (20 Points)</p> <p><input type="radio"/> 90 - 119 days (30 Points)</p> <p><input type="radio"/> < 90 days (40 Points)</p> <p><input type="radio"/> N/A (0 Points)</p> <p>6.2 If you checked N/A above, explain why.</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>		
<p>7. Issues</p> <p>7.1 Describe any outstanding biosolids issues with treatment, use or overall management:</p> <div style="border: 1px solid black; padding: 2px;">None</div>		

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 2025

Staffing and Preventative Maintenance (All Treatment Plants)

<p>1. Plant Staffing</p> <p>1.1 Was your wastewater treatment plant adequately staffed last year?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>Could use more help/staff for:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	
<p>2. Preventative Maintenance</p> <p>2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes (Continue with question 2) <input type="checkbox"/><input type="radio"/> No (40 points) <input type="checkbox"/> <p>If No, please explain, then go to question 3:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No (10 points) <p>2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<ul style="list-style-type: none"><input checked="" type="radio"/> Paper file system<input type="radio"/> Computer system<input type="radio"/> Both paper and computer system<input type="radio"/> No (10 points)	0
<p>3. O&M Manual</p> <p>3.1 Does your plant have a detailed O&M and Manufacturer Equipment Manuals that can be used as a reference when needed?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No	
<p>4. Overall Maintenance /Repairs</p> <p>4.1 Rate the overall maintenance of your wastewater plant.</p> <ul style="list-style-type: none"><input type="radio"/> Excellent<input checked="" type="radio"/> Very good<input type="radio"/> Good<input type="radio"/> Fair<input type="radio"/> Poor <p>Describe your rating:</p>	

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 **2025**

Maintenance is done on a regular basis the airlines in the SBR tanks could be switched out with schedule 40 piping for less breaks
--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 2025

Operator Certification and Education

<p>1. Operator-In-Charge</p> <p>1.1 Did you have a designated operator-in-charge during the report year?</p> <ul style="list-style-type: none"> <input checked="" type="radio"/> Yes (0 points) <input type="radio"/> No (20 points) <p>Name: <input style="width: 150px;" type="text" value="JOSHUA M KERN"/></p> <p>Certification No: <input style="width: 150px;" type="text" value="32581"/></p>	0																																																																																								
<p>2. Certification Requirements</p> <p>2.1 In accordance with Chapter NR 114.56 and 114.57, Wisconsin Administrative Code, what level and subclass(es) were required for the operator-in-charge (OIC) to operate the wastewater treatment plant and what level and subclass(es) were held by the operator-in-charge?</p> <table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2">Sub Class</th> <th rowspan="2">SubClass Description</th> <th colspan="2">WWTP</th> <th colspan="2">OIC</th> </tr> <tr> <th>Basic</th> <th>OIT</th> <th>Basic</th> <th>Advanced</th> </tr> </thead> <tbody> <tr><td>A1</td><td>Suspended Growth Processes</td><td>X</td><td></td><td>X</td><td></td></tr> <tr><td>A2</td><td>Attached Growth Processes</td><td></td><td></td><td>X</td><td></td></tr> <tr><td>A3</td><td>Recirculating Media Filters</td><td></td><td></td><td></td><td></td></tr> <tr><td>A4</td><td>Ponds, Lagoons and Natural</td><td></td><td></td><td></td><td></td></tr> <tr><td>A5</td><td>Anaerobic Treatment Of Liquid</td><td></td><td></td><td></td><td></td></tr> <tr><td>B</td><td>Solids Separation</td><td>X</td><td></td><td>X</td><td></td></tr> <tr><td>C</td><td>Biological Solids/Sludges</td><td>X</td><td></td><td>X</td><td></td></tr> <tr><td>P</td><td>Total Phosphorus</td><td>X</td><td></td><td>X</td><td></td></tr> <tr><td>N</td><td>Total Nitrogen</td><td></td><td></td><td></td><td></td></tr> <tr><td>D</td><td>Disinfection</td><td>X</td><td></td><td>X</td><td></td></tr> <tr><td>L</td><td>Laboratory</td><td></td><td></td><td></td><td></td></tr> <tr><td>U</td><td>Unique Treatment Systems</td><td></td><td></td><td></td><td></td></tr> <tr><td>SS</td><td>Sanitary Sewage Collection</td><td>X</td><td>X</td><td>NA</td><td>NA</td></tr> </tbody> </table> <p>2.2 Was the operator-in-charge certified at the appropriate level and subclass(es) to operate this plant? (Note: Certification in subclass SS is required 5 years after permit reissuance.)</p> <ul style="list-style-type: none"> <input checked="" type="radio"/> Yes (0 points) <input type="radio"/> No (20 points) <p>2.3 For wastewater treatment facilities with a registered or certified laboratory, is at least one operator that works in the laboratory certified at the basic level in the laboratory (L) subclass?</p> <ul style="list-style-type: none"> <input type="radio"/> Yes <input type="radio"/> No <input checked="" type="radio"/> N/A – Wastewater treatment facility does not have a registered or certified laboratory <p>2.4 For wastewater treatment facilities that own and operate a sanitary sewage collection system, has at least one operator been designated the OIC for sanitary sewage collection system and certified at the basic level in the sanitary sewage collection system (SS) subclass?</p> <ul style="list-style-type: none"> <input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A – Owner of the Wastewater treatment facility does not own and operate a sanitary sewage collection system 	Sub Class	SubClass Description	WWTP		OIC		Basic	OIT	Basic	Advanced	A1	Suspended Growth Processes	X		X		A2	Attached Growth Processes			X		A3	Recirculating Media Filters					A4	Ponds, Lagoons and Natural					A5	Anaerobic Treatment Of Liquid					B	Solids Separation	X		X		C	Biological Solids/Sludges	X		X		P	Total Phosphorus	X		X		N	Total Nitrogen					D	Disinfection	X		X		L	Laboratory					U	Unique Treatment Systems					SS	Sanitary Sewage Collection	X	X	NA	NA	0
Sub Class			SubClass Description	WWTP		OIC																																																																																			
	Basic	OIT		Basic	Advanced																																																																																				
A1	Suspended Growth Processes	X		X																																																																																					
A2	Attached Growth Processes			X																																																																																					
A3	Recirculating Media Filters																																																																																								
A4	Ponds, Lagoons and Natural																																																																																								
A5	Anaerobic Treatment Of Liquid																																																																																								
B	Solids Separation	X		X																																																																																					
C	Biological Solids/Sludges	X		X																																																																																					
P	Total Phosphorus	X		X																																																																																					
N	Total Nitrogen																																																																																								
D	Disinfection	X		X																																																																																					
L	Laboratory																																																																																								
U	Unique Treatment Systems																																																																																								
SS	Sanitary Sewage Collection	X	X	NA	NA																																																																																				
<p>3. Succession Planning</p> <p>3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?</p> <ul style="list-style-type: none"> <input checked="" type="checkbox"/> One or more additional certified operators on staff 																																																																																									

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 **2025**

<input type="checkbox"/> An arrangement with another certified operator <input checked="" type="checkbox"/> An arrangement with another community with a certified operator <input checked="" type="checkbox"/> An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year <input type="checkbox"/> A consultant to serve as your certified operator <input type="checkbox"/> None of the above (20 points) If "None of the above" is selected, please explain: <div style="border: 1px solid black; height: 20px; width: 100%; margin-top: 5px;"></div>	0
4. Continuing Education Credits 4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates? OIT and Basic Certification: <input checked="" type="radio"/> Averaging 6 or more CECs per year. <input type="radio"/> Averaging less than 6 CECs per year. Advanced Certification: <input type="radio"/> Averaging 8 or more CECs per year. <input type="radio"/> Averaging less than 8 CECs per year.	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 2025

Financial Management

<p>1. Provider of Financial Information</p> <p>Name: <input style="width: 150px;" type="text" value="Holly Malaszuk"/></p> <p>Telephone: <input style="width: 150px;" type="text" value="715-639-3792"/> (XXX) XXX-XXXX</p> <p>E-Mail Address (optional): <input style="width: 300px;" type="text" value="villelm@celectcom.net"/></p>													
<p>2. Treatment Works Operating Revenues</p> <p>2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ?</p> <p>● Yes (0 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ No (40 points)</p> <p>If No, please explain: <input style="width: 750px; height: 20px;" type="text"/></p> <p>2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised? Year: <input style="width: 100px;" type="text" value="2024"/></p> <p>● 0-2 years ago (0 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ 3 or more years ago (20 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ N/A (private facility)</p> <p>2.3 Did you have a special account (e.g., CWFPP required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system?</p> <p>● Yes (0 points)</p> <p>○ No (40 points)</p>	0												
<p>REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]</p>													
<p>3. Equipment Replacement Funds</p> <p>3.1 When was the Equipment Replacement Fund last reviewed and/or revised? Year: <input style="width: 100px;" type="text" value="2024"/></p> <p>● 1-2 years ago (0 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ 3 or more years ago (20 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ N/A</p> <p>If N/A, please explain: <input style="width: 750px; height: 20px;" type="text"/></p>													
<p>3.2 Equipment Replacement Fund Activity</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;">3.2.1 Ending Balance Reported on Last Year's CMAR</td> <td style="width: 5%; text-align: right;">\$</td> <td style="width: 35%; text-align: right;"><input style="width: 100%; border: 1px solid black;" type="text" value="78,942.00"/></td> </tr> <tr> <td>3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%; border: 1px solid black;" type="text" value="0.00"/></td> </tr> <tr> <td>3.2.3 Adjusted January 1st Beginning Balance</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%; border: 1px solid black;" type="text" value="78,942.00"/></td> </tr> <tr> <td>3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)</td> <td style="text-align: right;">+</td> <td style="text-align: right;"><input style="width: 100%; border: 1px solid black;" type="text" value="0.00"/></td> </tr> </table>	3.2.1 Ending Balance Reported on Last Year's CMAR	\$	<input style="width: 100%; border: 1px solid black;" type="text" value="78,942.00"/>	3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	\$	<input style="width: 100%; border: 1px solid black;" type="text" value="0.00"/>	3.2.3 Adjusted January 1st Beginning Balance	\$	<input style="width: 100%; border: 1px solid black;" type="text" value="78,942.00"/>	3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	+	<input style="width: 100%; border: 1px solid black;" type="text" value="0.00"/>	
3.2.1 Ending Balance Reported on Last Year's CMAR	\$	<input style="width: 100%; border: 1px solid black;" type="text" value="78,942.00"/>											
3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	\$	<input style="width: 100%; border: 1px solid black;" type="text" value="0.00"/>											
3.2.3 Adjusted January 1st Beginning Balance	\$	<input style="width: 100%; border: 1px solid black;" type="text" value="78,942.00"/>											
3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	+	<input style="width: 100%; border: 1px solid black;" type="text" value="0.00"/>											

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 2025

<p>3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*) - \$ 0.00</p> <p>3.2.6 Ending Balance as of December 31st for CMAR Reporting Year \$ 78,942.00</p> <p>All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.</p> <p>3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>3.3 What amount should be in your Replacement Fund? \$ 78,942.00</p> <p>Please note: If you had a CWFPP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the SectionInstructions link under Info header in the left-side menu.</p> <p>3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?</p> <p><input checked="" type="radio"/> Yes <input type="radio"/> No</p> <p>If No, please explain.</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	0								
<p>4. Future Planning</p> <p>4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?</p> <p><input type="radio"/> Yes - If Yes, please provide major project information, if not already listed below. <input type="checkbox"/> <input type="checkbox"/></p> <p><input checked="" type="radio"/> No</p> <table border="1" style="width: 100%; border-collapse: collapse; margin-top: 5px;"> <thead> <tr> <th style="width: 10%;">Project #</th> <th style="width: 60%;">Project Description</th> <th style="width: 15%;">Estimated Cost</th> <th style="width: 15%;">Approximate Construction Year</th> </tr> </thead> <tbody> <tr> <td colspan="4" style="text-align: center;">None reported</td> </tr> </tbody> </table>		Project #	Project Description	Estimated Cost	Approximate Construction Year	None reported			
Project #	Project Description	Estimated Cost	Approximate Construction Year						
None reported									
<p>5. Financial Management General Comments</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>									
<p>ENERGY EFFICIENCY AND USE</p>									
<p>6. Collection System</p> <p>6.1 Energy Usage</p> <p>6.1.1 Enter the monthly energy usage from the different energy sources:</p> <p>COLLECTION SYSTEM PUMPAGE: Total Power Consumed</p> <p>Number of Municipally Owned Pump/Lift Stations: <input style="width: 50px;" type="text" value="2"/></p>									

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:

6/1/2026

2025

	Electricity Consumed (kWh)	Natural Gas Consumed (therms)
January	242	
February	217	
March	229	
April	226	
May	243	
June	251	
July	406	
August	267	
September	251	
October	221	
November	195	
December	233	
Total	2,981	0
Average	248	0

6.1.2 Comments:

6.2 Energy Related Processes and Equipment

6.2.1 Indicate equipment and practices utilized at your pump/lift stations (Check all that apply):

- Comminution or Screening
- Extended Shaft Pumps
- Flow Metering and Recording
- Pneumatic Pumping
- SCADA System
- Self-Priming Pumps
- Submersible Pumps
- Variable Speed Drives
- Other:

6.2.2 Comments:

6.3 Has an Energy Study been performed for your pump/lift stations?

- No
- Yes

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 **2025**

6.4 Future Energy Related Equipment

6.4.1 What energy efficient equipment or practices do you have planned for the future for your pump/lift stations?

upgrade pumps as needed

7. Treatment Facility

7.1 Energy Usage

7.1.1 Enter the monthly energy usage from the different energy sources:

TREATMENT PLANT: Total Power Consumed/Month

	Electricity Consumed (kWh)	Total Influent Flow (MG)	Electricity Consumed/ Flow (kWh/MG)	Total Influent BOD (1000 lbs)	Electricity Consumed/ Total Influent BOD (kWh/1000lbs)	Natural Gas Consumed (therms)
January	14,679	1.75	8,388	4.22	3,478	
February	17,033	1.51	11,280	3.25	5,241	
March	9,786	1.82	5,377	6.79	1,441	
April	9,128	1.66	5,499	3.48	2,623	
May	10,152	1.61	6,306	4.34	2,339	
June	8,844	1.67	5,296	3.78	2,340	
July	10,615	2.34	4,536	4.99	2,127	
August	10,629	1.57	6,770	3.60	2,953	
September	9,603	1.63	5,891	3.63	2,645	
October	7,539	1.64	4,597	3.10	2,432	
November	7,739	1.52	5,091	3.21	2,411	
December	14,739	1.51	9,761	3.50	4,211	
Total	130,486	20.23		47.89		0
Average	10,874	1.69	6,566	3.99	2,853	0

7.1.2 Comments:

7.2 Energy Related Processes and Equipment

7.2.1 Indicate equipment and practices utilized at your treatment facility (Check all that apply):

- Aerobic Digestion
- Anaerobic Digestion
- Biological Phosphorus Removal
- Coarse Bubble Diffusers
- Dissolved O2 Monitoring and Aeration Control
- Effluent Pumping
- Fine Bubble Diffusers
- Influent Pumping
- Mechanical Sludge Processing
- Nitrification
- SCADA System
- UV Disinfection
- Variable Speed Drives
- Other:

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 2025

7.2.2 Comments:

7.3 Future Energy Related Equipment

7.3.1 What energy efficient equipment or practices do you have planned for the future for your treatment facility?

8. Biogas Generation

8.1 Do you generate/produce biogas at your facility?

- No
- Yes

If Yes, how is the biogas used (Check all that apply):

- Flared Off
- Building Heat
- Process Heat
- Generate Electricity
- Other:

9. Energy Efficiency Study

9.1 Has an Energy Study been performed for your treatment facility?

- No
- Yes

Entire facility

Year:

By Whom:

Describe and Comment:

Part of the facility

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 **2025**

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 2025

Sanitary Sewer Collection Systems

1. Capacity, Management, Operation, and Maintenance (CMOM) Program

1.1 Do you have a CMOM program that is being implemented?

- Yes
- No

If No, explain:

1.2 Do you have a CMOM program that contains all the applicable components and items according to Wisc. Adm Code NR 210.23 (4)?

- Yes
- No (30 points)
- N/A

If No or N/A, explain:

1.3 Does your CMOM program contain the following components and items? (check the components and items that apply)

- Goals [NR 210.23 (4)(a)]

Describe the major goals you had for your collection system last year:

Cleaning 25% of the collection system plus cleaning of the lift stations

Did you accomplish them?

- Yes
- No

If No, explain:

- Organization [NR 210.23 (4) (b)]

Does this chapter of your CMOM include:

- Organizational structure and positions (eg. organizational chart and position descriptions)
- Internal and external lines of communication responsibilities
- Person(s) responsible for reporting overflow events to the department and the public

- Legal Authority [NR 210.23 (4) (c)]

What is the legally binding document that regulates the use of your sewer system?

sewer ordinance

If you have a Sewer Use Ordinance or other similar document, when was it last reviewed and revised? (MM/DD/YYYY) 2002-11-11

Does your sewer use ordinance or other legally binding document address the following:

- Private property inflow and infiltration
- New sewer and building sewer design, construction, installation, testing and inspection
- Rehabilitated sewer and lift station installation, testing and inspection
- Sewage flows satellite system and large private users are monitored and controlled, as necessary
- Fat, oil and grease control
- Enforcement procedures for sewer use non-compliance

- Operation and Maintenance [NR 210.23 (4) (d)]

Does your operation and maintenance program and equipment include the following:

- Equipment and replacement part inventories
- Up-to-date sewer system map
- A management system (computer database and/or file system) for collection system information for O&M activities, investigation and rehabilitation

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 2025

- A description of routine operation and maintenance activities (see question 2 below)
 - Capacity assessment program
 - Basement back assessment and correction
 - Regular O&M training
 - Design and Performance Provisions [NR 210.23 (4) (e)]
- What standards and procedures are established for the design, construction, and inspection of the sewer collection system, including building sewers and interceptor sewers on private property?
- State Plumbing Code, DNR NR 110 Standards and/or local Municipal Code Requirements
 - Construction, Inspection, and Testing
 - Others:

- Overflow Emergency Response Plan [NR 210.23 (4) (f)]
- Does your emergency response capability include:
- Responsible personnel communication procedures
 - Response order, timing and clean-up
 - Public notification protocols
 - Training
 - Emergency operation protocols and implementation procedures
- Annual Self-Auditing of your CMOM Program [NR 210.23 (5)]
 - Special Studies Last Year (check only those that apply):
- Infiltration/Inflow (I/I) Analysis
 - Sewer System Evaluation Survey (SSES)
 - Sewer Evaluation and Capacity Management Plan (SECAP)
 - Lift Station Evaluation Report
 - Others:

2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning	<input style="width: 100px; text-align: center;" type="text" value="25"/>	% of system/year
Root removal	<input style="width: 100px; text-align: center;" type="text" value="25"/>	% of system/year
Flow monitoring	<input style="width: 100px; text-align: center;" type="text" value="0"/>	% of system/year
Smoke testing	<input style="width: 100px; text-align: center;" type="text" value="0"/>	% of system/year
Sewer line televising	<input style="width: 100px; text-align: center;" type="text" value="5"/>	% of system/year
Manhole inspections	<input style="width: 100px; text-align: center;" type="text" value="10"/>	% of system/year
Lift station O&M	<input style="width: 100px; text-align: center;" type="text" value="2"/>	# per L.S./year
Manhole rehabilitation	<input style="width: 100px; text-align: center;" type="text" value="0"/>	% of manholes rehabbed
Mainline rehabilitation	<input style="width: 100px; text-align: center;" type="text" value="0"/>	% of sewer lines rehabbed
Private sewer inspections	<input style="width: 100px; text-align: center;" type="text" value="0"/>	% of system/year
Private sewer I/I removal	<input style="width: 100px; text-align: center;" type="text" value="0"/>	% of private services

0

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 **2025**

River or water crossings % of pipe crossings evaluated or maintained

Please include additional comments about your sanitary sewer collection system below:

3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

<input type="text" value="25.67"/>	Total actual amount of precipitation last year in inches
<input type="text" value="34"/>	Annual average precipitation (for your location)
<input type="text" value="6.571"/>	Miles of sanitary sewer
<input type="text" value="2"/>	Number of lift stations
<input type="text" value="0"/>	Number of lift station failures
<input type="text" value="0"/>	Number of sewer pipe failures
<input type="text" value="1"/>	Number of basement backup occurrences
<input type="text" value="2"/>	Number of complaints
<input type="text"/>	Average daily flow in MGD (if available)
<input type="text"/>	Peak monthly flow in MGD (if available)
<input type="text"/>	Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

<input type="text" value="0.00"/>	Lift station failures (failures/year)
<input type="text" value="0.00"/>	Sewer pipe failures (pipe failures/sewer mile/yr)
<input type="text" value="0.00"/>	Sanitary sewer overflows (number/sewer mile/yr)
<input type="text" value="0.15"/>	Basement backups (number/sewer mile)
<input type="text" value="0.30"/>	Complaints (number/sewer mile)
<input type="text"/>	Peaking factor ratio (Peak Monthly:Annual Daily Avg)
<input type="text"/>	Peaking factor ratio (Peak Hourly:Annual Daily Avg)

4. Overflows

LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OVERFLOWS REPORTED **

Date	Location	Cause	Estimated Volume
None reported			

** If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

- Yes
- No

If Yes, please describe:

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

- Yes
- No

If Yes, please describe:

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 **2025**

<input type="text"/>
5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:
<input type="text" value="None"/>
5.4 What is being done to address infiltration/inflow in your collection system?
<input type="text" value="Replace clay sewer main on street projects when possible"/>

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:

6/1/2026

2025

Grading Summary

WPDES No: 0023922

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	A	4	3	12
BOD/CBOD	C	2	10	20
TSS	B	3	5	15
Ammonia	B	3	5	15
Phosphorus	B	3	3	9
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS			37	115
GRADE POINT AVERAGE (GPA) = 3.11				

Notes:

A = Voluntary Range (Response Optional)

B = Voluntary Range (Response Optional)

C = Recommendation Range (Response Required)

D = Action Range (Response Required)

F = Action Range (Response Required)

Compliance Maintenance Annual Report

Elmwood, Village Of Wwtf

Last Updated: Reporting For:
6/1/2026 2025

Resolution or Owner's Statement

Name of Governing
Body or Owner:

Date of Resolution or
Action Taken:

Resolution Number:

Date of Submittal:

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR SECTIONS (Optional for grade A or B. Required for grade C, D, or F):

Influent Flow and Loadings: Grade = A

Effluent Quality: BOD: Grade = C

Effluent Quality: TSS: Grade = B

Effluent Quality: Ammonia: Grade = B

Effluent Quality: Phosphorus: Grade = B

Biosolids Quality and Management: Grade = A

Staffing: Grade = A

Operator Certification: Grade = A

Financial Management: Grade = A

Collection Systems: Grade = A

(Regardless of grade, response required for Collection Systems if SSOs were reported)

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL GRADE POINT AVERAGE AND ANY GENERAL COMMENTS

(Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)

G.P.A. = 3.11

